

Single Window Clearance System

Directorate of Industries(DOI) Govt. of Himachal Pradesh

DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2

NO OBJECTION CERTIFICATE

TO WHOM IT MAY CONCERN

That the premises of Indus Global School India Vill. Jarly Gagal Road. Tehsil Sadar Distt. Mandi HP. was inspected on 2023-05-2 with reference to his application No. App/10/06/21/8/434 dated 2021-10-06 14:38:32 by, the incharge Fire Station FS mandi with regard to measures adopted for protection against fire and it has been reported/recommended.

- That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed for two years w.e.f. 06/05/2023 to 05/05/2025 subject to fulfilment of the following conditions:-
 - 1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
 - 2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/system in perfect running condition, failing which this certificate shall be treated as cancelled.
 - 3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and \ written record shall be kept in the premises for the inspection of fire services.

4. Good House keeping must be maintained within the premises.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function where temporary structures and Pandals are to be erected.

[Digitally Signed 06-05-2023 15:26:41]

Chief Fire Officer.

Himachal Pradesh Shimla-2

Place: Shimla Dated: 2023-05-06

Indus Global School (India)

Mandi (H.P.)